

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7165-1130:166 Page 1 of 1

**CATEGORY:** Control Unit (Non High-Rise)

**LISTEE:** Honeywell International Inc., 1500 West Dundee Road, Arlington Heights, IL 60004-1472  
Contact: Bob Hodgson (847) 797-4403 Fax (847) 797-3664

**DESIGN:** Models XLS-2Z3, XLS-2Z3-R, XLS-2Z6 and XLS-2Z6-R fire alarm control units. Local, auxiliary, central station, remote station, automatic, manual, waterflow and sprinkler supervisory service. System components:

MODEL	DESCRIPTION
2IDC	2 Zone Initiating Module
BPAC	Base Panel Class A Converter
IDCA	IDC Module Class A Converter
RCT-1	Relay-City Tie (FDR) Module
ADMM	Annunciator Master Module
ADSM	Annunciator Slave Module
DL1	Digital Alarm Comm Transmitter

Refer to listee's data sheet for additional detailed product description and operational considerations.

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as fire alarm control units for use with separately listed compatible initiating and indicating devices.

This control unit does not generate a temporal pattern signal. If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition is required, the control unit must be used with appliances that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for details.

**NOTE:** For Alarm Verification Feature, the maximum Retard/Reset/Restart period must be adjusted to 30 seconds or less.

**XLF:** \*7165-1591:164 Formerly 7165-1388:177

\*Rev. 05-24-2004



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**JUNE 22, 2004**

*Listing Expires **June 30, 2005***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager